General Plumbing Plan Review Application



inches

Project Informat	ion – Fill in	all known	information:
------------------	---------------	-----------	--------------

Building, Project, or Te	enant Name:				
Previous Te	enant Name:				
Project Stre	eet Address:				
City/Sta	te/ZIP Code:				
Project Scope:					
Designer Information:					
Designer Name:					
License Number:					
Email:					
Phone number:					
Company:					
Address:					
City/State/ZIP Code:					
Type of Submittal - Che	eck all that ap	pply:			
☐ New Construction			☐ Permission to Start (verify eligibility on page 2)		
☐ Addition			\square Extension to a previously approved plan		
\square Alteration			☐ Multiple identical buildings		
☐ Revision to previously approved Plans Number of Buildings:					
Project Specific Inform	nation – Fill ir	n all known infor	mation:		
Indicate the total number of interior fixtures ¹ , including roof drains and hose			Total		
bibs included in this submittal:				Fixtures ¹	
Building area (New Construction & Addition projects only):			Sq. Ft.		
Storm Area drained to a plumbing system:			Acres		
Combined size in inches of water supply and sanitary lateral(s) serving				:	

- (a) Is either permanently or temporarily connected to the water supply system of the premises and demands a supply of water from the system.
- (b) Discharges wastewater or waste materials either directly or indirectly to the drain system of the premises.
- (c) Requires both a water supply connection and a discharge to the drain system of the premises.

structure:

^{1&}quot;Plumbing fixture" means a receptacle or device which meets at least one of the following:

Types of Installation Components (Equipment Types) - Check all that apply: ☐ IAPMO Water Demand Calculator ☐ Building Drain & Vent, Sanitary¹ ☐ Regulated Contaminant Water ☐ Building Drain & Vent, Storm¹ Treatment - Other² ☐ Interior Containment Tank ☐ Regulated Contaminant Water ☐ Building Sewer, Sanitary¹ ☐ Interior Cross Connection Control Treatment – Radium² ☐ Building Sewer, Storm¹ Assembly, Health Care ☐ Sanitary Dump Station ☐ Campground/Recreational Vehicle ☐ Interior Grease Interceptor ☐ Siphonic Roof Drain Engineered Park Drainage System, Sanitary ☐ Interior Mixed Wastewater Treatment System ☐ Campground/Recreational Vehicle Device ☐ Sovent Engineered System*** Park Drainage System, Storm ☐ Interior Non-Potable Water System ☐ Storm Detention System ☐ Campground/Recreational Vehicle ☐ Interior Oil Interceptor \square Storm Subsurface Infiltration Park Water Supply System ☐ Interior Potable Water Tank Plumbing² ☐ Car Wash Interceptor ☐ Interior Wastewater Treatment □ Water Distribution System¹ ☐ Chemical Waste System Device ☐ Water Reuse - Blackwater² ☐ Controlled Roof Drain Engineered ☐ Manufactured Home Community ☐ Water Reuse - Clearwater² System Water Supply System ☐ Drainage System, Storm ☐ Water Reuse – Graywater² ☐ Multipurpose Piping System ☐ Exterior Containment Tank ☐ Water Reuse – Stormwater² ☐ Private Interceptor Main Sewer, ☐ Exterior Cross Connection Control □ Water Service¹ Sanitary¹ Assembly, Health Care ☐ Water Treatment – .5 Chlorine² ☐ Private Interceptor Main Sewer, \square Exterior Grease Interceptor ☐ Water Treatment – Chloramine² Storm¹ ☐ Exterior Mixed Wastewater Treatment ☐ Water Treatment – Chlorine ☐ Private Water Main¹ Device Dioxide² ☐ Provent Engineered System*** ☐ Exterior Non-Potable Water System ☐ Water Treatment – Silver/Copper² ☐ Pure Water System (RO) ☐ Exterior Oil Interceptor ☐ Water Treatment – Thermal² ☐ Regulated Contaminant Water ☐ Exterior Potable Water Tank ☐ Water Treatment – Ultrafiltration² Treatment - Arsenic² ☐ Exterior Wastewater Treatment ☐ Water Treatment – Ultraviolet ☐ Regulated Contaminant Water Device, Storm Svstem² Treatment - Bacteria² ☐ Garage Catch Basin ☐ Alternate Vacuum Waste System ☐ Regulated Contaminant Water ☐ Hospitals, Surgery Centers & CBRFs² Treatment - Nitrate² *** Submit to DSPS for review. We cannot review Provent, Sovent or other similarly classified Experimental Systems. ¹ Permission to Start can be applied for. ² Delegated authority for this installation is municipal specific. Check the current list of delegated municipalities to determine whether this installation can be submitted to E-Plan Exam or if it needs to be submitted to DSPS for review. **Attestation** The applicant acknowledges that the submittal is complete and accurate, and that any additional application or submittal information requested must be received within five (5) business days or the plan is subject to denial. The applicant further acknowledges that any additional plan review information requested must be received within fifteen (15) business days or the plan is subject to denial. **Applicant Signature** Date **Applicant Name: Applicant Email:**

E-Plan Exam - Plumbing Plan Review Application

Applicant Phone:

Optional - Permission to Start Request:

The request for an early Permission to Start is optional and an additional fee will be applied. As specified within the <u>Alternate Approval</u>, a submittal of a complete set of plans is required to utilize the permission to start. Scope of installations are limited to below grade only and a maximum of 18-inches above floor.

As the building owner, I request to begin plumbing installations prior to plan review approval I agree to make any changes required after plans have been reviewed, and to remove or replace any non-code complying construction and make revisions to plans on any changes. I will not permit any installation to exceed 18 inches above the unexcavated floor.

Request is for the following specific plumbing insta	allations:	
 □ Building drain & vent, sanitary □ Building drain & vent, storm □ Building sewer, sanitary □ Building sewer, storm □ Private interceptor main sewer, sanitary 	 □ Private interceptor main □ Private water main □ Water distribution syster □ Water service 	
Building Owner's Signatu	re	Date
Building Owner's Printed Name:		_
Building Owner's Email:		_
Building Owner's Phone:		

E-Plan Exam - Plumbing Plan Review Application

E-Plan Exam - Plumbing Plan Review Checklist

Site Specific Requirements:
□ Plot plan showing the locations, sizes, and slopes of all sanitary sewers, storm sewers (including the roof drain system), and water service piping within the property lines.
☐ Each segment of piping shall have GPM flow rates, the maximum capacity next to each pipe size and the slope. Include all pipe sizes and discharge rates. Include piping profiles where applicable.
\square Site grade run off plans and contour lines showing what is drained to the plumbing system.
\square Geotechnical reports must not be included in the Site-Specific Plan.
□ Stormwater and Clearwater Disposal Systems plans shall include:
\square Roof drainage, site grade run off, and contour lines showing the entire drainage area.
\square Include details of all stormwater structures (Catch Basins, Inlets Manholes etc.) and any other system components.
\square Show all pipe sizes and discharge rates after each inlet.
\Box Complete Storm System design calculations as required <u>SPS 382.36(6)</u> .
\square Cross section of ponds, swales, etc.
Building Specific Requirements:
☐ Plan(s) must include complete plumbing floor plans for each floor that show all sizes and locations of horizonal sanitary, storm, and water distribution lines along with the location of fixtures and equipment to be installed.
Note: Remodeling or additions shall include existing loads.
☐ Provide 30°/60° isometric diagrams of the drain, vent, water distribution, and interior storm systems. Include detailed drawings of specific areas (i.e. mechanical room, water meter room, R.P. valves, etc.) where applicable.
\Box Isometric drawings shall include water supply & drainage fixture units and pipe sizes on each segment of piping.
$\hfill\Box$ Isometric drawings shall include pipe sizes and GPM loads on each segment of storm/clearwater piping.
\square Isometric drawings shall include secondary overflow drain piping.
\square Roof Plan showing drainage areas, GPM loads, drains and sizes of scuppers and/or secondary overflow drain systems per IBC 1611.3.
☐ Complete water calculations in accord with <u>SPS 382.40(7)</u> . Water calculations may be located on the plans; however, one copy of the calculations must be submitted separately from the plan documents. Links below for instructions and form.
https://dsps.wi.gov/Documents/Programs/Plumbing/SBD6479Instructions.pdf
https://dsps.wi.gov/Documents/Programs/Plumbing/SBD6479.pdf
General Requirements for all plans:
☐ All plans shall be properly signed per <u>SPS 382.20(4)(c)</u> . The submittal shall be limited to plans pertinent to the plumbing review.
☐ Specifications/Cut sheets or shop drawings of all plumbing fixtures, appliances, or equipment. This includes all exterior catch basin, inlets, manholes or other storm disposal devices.
\Box Fixtures requiring water or waste connections may need product approval. Include DSPS product approval letters for those fixtures.
☐ Complete sizing calculations for grease, oil, or car wash interceptors as required by SPS 382.34.

E-Plan Exam - Plumbing Plan Review Application

Optional Sizing of Water Supply Piping using IAPMO Water Demand Calculator

□ As the applicant, I am requesting to use the IAPMO Water Demand Calculator v. 2.2 for sizing the water supply piping in accordance with SPS 382.40(7) outlined in the alternate approval. I understand this alternate standard provides a method for estimating the demand load for the building water supply and principal branches for nonpublic multiple dwellings, as defined by s. SPS 381.01(155) and (162) Wis. Adm. Code, with water conserving plumbing fixtures, fixture fittings and appliances.

The applicant acknowledges the following items:

- Review and include a copy of the DSPS approval <u>PP-031603529-PTOAA</u> letter with the IAPMO WDC submittal.
- Provide verbiage for a sign or posting with permanent tagging at the building control valve and water heater control valve to identify the specific IAPMO Water Demand Calculator Sizing system.
- Provide IAPMO WDC calculations for each piece of distribution piping using the IAPMO WDC sizing method.
- All piping sized using the IAPMO WDC alternative shall display bold, underlined and italicized GPM loads on the isometric plan sheets.
- WSFUs shall not be combined with WDC GPM's (mains or vertical risers); therefore, provide actual fixture GPMs loads for each non WDC fixture, if adding to the WDC method distribution system. Separate water distribution piping systems may use Wis Code SPS 382.40(7) WSFU's provided they are connected upstream of the beginning of any IAPMO WDC system method sizing piping.
- Water distribution piping ½" or ¾" in diameter serving plumbing fixtures shall not have a load greater than those assessed per pressure available for uniform loss ("A" value) in Tables SPS 382.40 4-11 Wis. Adm. Code and tables for ASTM D1785 and ASTM F441 in the appendix.
- All fixtures and replacement fixtures shall be at or below the designed fixture flow rates and shall be Energy Star rated for the IAPMO Water Demand Calculator Sizing system. Provide fixture cut sheets with low flow & energy star certification with the IAPMO submittal.
- Water supply piping shall be sized and installed in strict accordance with IAPMO Water Demand Calculator, <u>Chapters SPS 381-386 Wis. Adm. Code</u> and the alternate approval.

Notes

The following types of review **must** be submitted to the Department of Safety and Professional Services for plumbing plan review:

- Experimental Plumbing Systems including, but not limited to, Provent Drainage Systems
- Reduced pressure principle backflow preventer registration